

**Republic of the Philippines**  
**Department of Science and Technology**  
**PHILIPPINE SCIENCE HIGH SCHOOL – MAIN CAMPUS**  
**Agham Road, Diliman, Quezon City**

**Bids and Award Committee – Infrastructure**

## BID BULLETIN NO. 1

(April 6, 2018)

This Bid Bulletin No 1 is issued to modify or amend items in the Bid Document with Solicitation No.: 18-03-025 on the procurement of (a) Site Development: Rehabilitation of the Guardhouse, Track and Field and Improvement of Campus Grounds; and (b) Installation of Main Power Supply Cable for the Residence Halls.

In the pre-bid conference conducted on March 26, 2018, the following revisions in the bid documents were effected:

**1. Section V – Special Conditions of Contract**

GCC Clause	Before Bid Bulletin	After Bid Bulletin
2.2	The acquisition of: <ol style="list-style-type: none"> <li>1. Certificate of Electrical Inspection or CEI or for the construction of the power house; and</li> <li>2. All necessary permits required by the government agencies concerned in the issuance of the CEI which include but are not limited to buildings permits, ECC or CNCC, etc.</li> </ol>	The acquisition of: <ol style="list-style-type: none"> <li>1. Certificate of Electrical Inspection or CEI or for the construction of the power house;</li> <li>2. Tree cutting permit from the Barangay and the DENR, and</li> <li>3. All necessary permits required by the government agencies concerned in the issuance of the CEI which include but are not limited to buildings permits, ECC or CNCC, etc.</li> </ol>

**2. Section VI - Specifications**

	Before Bid Bulletin	After Bid Bulletin
1.	<u><b>General Requirements</b></u> 1.2	<u><b>General Requirements</b></u> <i>1.2 The Contractor shall be responsible for securing the Tree cutting permit from the Barangay and the DENR.</i>
5.3	<u><b>Scope of Work</b></u>  <b>5.Construction</b> Processing and Securing of Permits and Insurance The contractor shall be responsible for securing the <b>Certificate of Electrical Inspection (CEI)</b> for the Construction of the Powerhouse and all necessary permits required by the government agencies concerned in the issuance of the CEI, which shall include but are not limited to Building Permits, ECC or CNC, etc., Contractor’s All Risk Insurance & Third Party Liability and Workman’s	<u><b>Scope of Work</b></u>  <b>5.Construction</b> Processing and Securing of Permits and Insurance The contractor shall be responsible for securing the <b>Certificate of Electrical Inspection (CEI)</b> for the Construction of the Powerhouse and all necessary permits required by the government agencies concerned in the issuance of the CEI, which shall include but are not limited to

	<p>Compensation Insurance (CARI), and other insurances required by the Local Government Unit (LGU), among others, including payment of assessed fees as may be required by the LGU and/or Regulating Agencies before the implementation of the project. All related documents shall be submitted to the Philippine Science - Main Campus.</p>	<p>Building Permits, ECC or CNC, etc., Contractor's All Risk Insurance &amp; Third Party Liability and Workman's Compensation Insurance (CARI), and other insurances required by the Local Government Unit (LGU), among others, including payment of assessed fees as may be required by the LGU and/or Regulating Agencies before the implementation of the project. All related documents shall be submitted to the Philippine Science - Main Campus.</p> <p><b><i>The contractor shall be responsible for securing the Tree Cutting Permit form the Barangay and the DENR.</i></b></p>
--	---	---


### 3. Bidders Written Query

	<b>Bidders Written Query</b>	<b>BAC Answer</b>
1	For the rehabilitation of Brass Signage, please provide the size of brass signage	Dimension of brass signages, 2' x 3':flatten & reinstallation
2	Please provide the length for reform bars	Deform bar length used: 6m
3	Please clarify the wires/cables that was included in the construction of powerhouse, service entrance & load schedule of LVSG	Indicated on the ABAA drawings
4	Please provide the dimension for septic tank	LDPE 2500 liter capacity; 3040mm (L) x 1010mm (W) x 1080mm (H); with manhole cover, desludging port & cover, and gas venting port
5	Please confirm the changes regarding the quantities in the BOQ since we have revisions to the plan. If any. Please send us the updated BOQ.	Updated BOQ ver. 040618 posted in website of PSHS-MC ( <a href="http://www.mc.pshs.edu.ph">http://www.mc.pshs.edu.ph</a> ) or PhilGEPS website ( <a href="http://www.philgeps.gov.ph">http://www.philgeps.gov.ph</a> )

4. Bid opening shall be move on April 13, 2018 at 9:00am. Deadline of submission of bids is on April 13, 2018 at 8:30am.

For guidance and Information of all concerned.

Approved by:

  
**MARY JANE L. TURINGAN**  
 BAC Chairperson - Infrastructure